

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND  
SANITARY CONDITION

CERTIFICATE

No. 697

Date: 9/9/2024

It is certified that an inspection team headed by Water Supply & Sanitation Sub Division Officials inspected BK International Convent School on 06-09-2024 and found that **BK International Convent School** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus is satisfactory.

The above valid for a period of **6 Months**.

Signature with Seal:   
Sub Divisional Engineer  
W/S & Sanitation  
Name :   
Sub Division Shahkot  
Designation :   
J.E.

To

BK International Convent School

Wara Jodh Singh, Block Lohian Khas

Jalandhar

  
Principal  
**BK International Convent School**  
Wara Jodh Singh (Jal.)  
Wara Jodh Singh (Jal.)  
Principal  
Principal  
Principal  
Principal

# DISTRICT WATER TESTING LABORATORY, JALANDHAR

Water Supply and Sanitation Office, Near Bara Darl, Near DC Office, Jalandhar  
dwtljalandhar@gmail.com

To,

BK International Convent School, Wara Jodh Singh.  
Distt. Jalandhar

No.: DWTLJAL/2425/00126 Dated : 23/07/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 038/2024 Dated: 15/07/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 16/07/2024. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Jalandhar

Y/A : Test Report



Authorized Signatory  
For, District water Testing Laboratory  
Jalandhar



Principal  
**BK International Convent School**  
**Wara Jodh Singh (Jal.)**

# DISTRICT WATER TESTING LABORATORY, JALANDHAR

Water Supply and Sanitation Office, Near Bara Darl, Near DC Office, Jalandhar  
dwtljalandhar@gmail.com

TEST REPORT						
Name & Address of Customer : BK International Convent School, Wara Jodh Singh. Distt. Jalandhar	Customer Reference No.	No : 038/2024 Dated : 15/07/2024				
	Sample Submitted by	Smt. Mehak Wadhwa				
	Date of Sample Receipt	16/07/2024				
	Analysis Starting Date	17/07/2024				
	Analysis completion Date	18/07/2024				
Discipline : Chemical Testing	Group: Water					
ULR No.:	Sample Type :	Water				
Test Report No.:	DWTLJAL/2425/00126	Date of Issue :	23/07/2024			
Registration no.:	DWTLJAL/REG2425/00332	Condition of Sample :	Unsealed			
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Amber Coloured Sample Bottle - 500 mL			
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	BK International Convent School, Wara Jodh Singh, Distt. Jalandhar.(P/Sub.) / NA			
Village :	Bara Jodh Singh	Habitation :	Bara Jodh Singh			
Block:	Lohian Khas	District :	Jalandhar			
Latitude :	Not Mentioned	Longitude:	Not Mentioned			
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	9.03@25°C	6.5-8.5	No Relaxation	—	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025 (Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	—	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	—	IS 3025 (Part 8 – 2023)
5	TDS	70.0	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.5	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO <sub>3</sub> )	44.44	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO <sub>3</sub> )	32.64	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium(Ca)	9.81	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium(Mg)	1.98	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	11.57	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit: 50 ±20%

Reviewed and Approved By



Mr. Jivesh Kumar  
Quality Manager  
Authorized Signatory  
For, District water Testing Laboratory  
Jalandhar

*Neetu*  
Principal  
BK International Convent School  
Wara Jodh Singh (Jal.)

End of the Test Report